



Symbol Description:

AP1	Main Control Board	MF2 <sub>1,2</sub>	TH4 <sub>4</sub>	Ambient Temperature
AP2	Switching Power Supply Board	PUMMP		
AP3	Remote Control Panel	EXV		
XT	Power Terminal Block	TH1 <sub>1</sub>		
KM	AC Contactor	TH2 <sub>2</sub>		
MF1	Fan Motor	TH3 <sub>3</sub>		

- Notice:
- 1.The communication line is connected by a shielded twisted pair.
  - 2.No electric heating models do not require contactors and electric heating.
  - 2.The wireless controller models do not need a wire controller.

S3: Model、Function Code		Num	Function	0	1
S3-1				/	/
S3-2	No			/	/
S3-3	Electric Heating2	No Electric Heating2	Electric Heating2		
S3-4	Electric Heating1	No Electric Heating1	Electric Heating1		

  

S1: Internal Capability Code								
Indoor Model	S1-1	S1-2	S1-3	S1-4	S1-5	S1-6	S1-7	S1-8
TM**022	0	0	1	0	1	1	1	0
TM**025	0	0	1	1	0	0	1	1
TM**028	0	0	1	1	1	0	0	0
TM**032	0	0	1	0	0	0	0	0
TM**036	0	0	1	0	0	1	0	0
TM**040	0	0	1	0	1	0	0	0
TM**045	0	0	1	0	1	1	0	1
TM**050	0	0	1	1	0	0	1	0
TM**056	0	0	1	1	1	0	0	0
TM**063	0	0	1	1	1	1	1	1
TM**071	0	0	1	0	0	1	1	1
TM**080	0	1	0	1	0	0	0	0
TM**090	0	1	0	1	1	0	1	0
TM**100	0	1	1	0	0	1	0	0
TM**112	0	1	1	1	0	0	0	0
TM**125	0	1	1	1	1	1	0	1
TM**140	1	0	0	0	1	1	0	0

  

Wire Controller (Need to be connected with the wire controller model)		EXV	MF2	MF2
TMDF	0	1	1	1
TWCS	0	1	1	1
TWCD	1	0	0	0